



# CERTIFICATE

<b>Certificate holder</b>	<b>FISCHER Mess- und Regeltechnik GmbH</b> <b>Bielefelder Str. 37a</b> <b>32107 Bad Salzuflen</b> <b>GERMANY</b>
<b>Product</b>	Flow switches for heat transfer installations
<b>Type, Model</b>	DS21...
<b>Testing basis</b>	DIN 4754-2:2015-03 Zertifizierungsprogramm Strömungs- und Füllstandsicherungen (2016-01)
<b>Mark of conformity</b>	
<b>Registration No.</b>	10S001
<b>Valid until</b>	2025-10-31
<b>Right of use</b>	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.  See annex for further information.

2020-12-21

  
Dipl.-Wi.-Ing. (FH) Sören Scholz  
Head of Certification Body



# ANNEX

Page 1 of 1

<b>Certificate</b>	10S001 dated 2020-12-21
<b>Technical Data</b>	Model: differential pressure gauge Operating pressure: 6 bar, 10 bar and 16 bar (according to design) Rated voltage: 250 V AC, 5 A or 30 V DC, 0,4 A Switching hysteresis: 2,5 % accumulated value of measuring range
<b>Testing laboratory/ Inspection body</b>	TÜV Rheinland Industrie Service GmbH Am Grauen Stein 51105 Köln GERMANY
<b>Test report(s)</b>	SSW 1710/15 dated 2015-10-07 968/FI 1018.00/18 dated 2018-09-24 968/FI 1018.01/19 dated 2019-09-27 968/FSP 2160.00/20 dated 2020-11-25

