developing solutions





Data sheet DA01 VUW

Differential pressure measuring device Pressure levels PN250/PN400

Standard version



09015036 • DB_EN_DA01_VUW • Rev. ST4-E • 03/25

1 Product and functional description

1.1 Performance features

Typical applications

- · Chemical, petrochemical industry
- Process technology
- Marine and offshore technology
- · Power plant technology
- Mechanical and plant engineering

Important features

- · Highly corrosion resistant
- CrNi-steel model
- Use with aggressive media
- Highly durable
- Variable connection technology
- With fluid filling as an option
- Optional additional equipment such as contact element or rotation angle encoder

1.2 Equipment versions

The following illustrations depict typical combinations of the measuring cell, measured value display and contact elements. However, these can be freely combined according to the order code. Wherever this is not possible, this is clearly stated.

For instance, a small measuring cell with an NG160 display and a contact element is also available.



Large measuring cell Ø130 (mbar ranges)



Small measuring cell Ø75 (bar ranges)

Fig. 1: Device overview



Fig. 2: Options for the process connection

1.2.2 Contact devices

NOTICE! No changeover contacts possible



Limit switch in accordance with data sheet KE##	Rotation angle encoder in accordance with data sheet KE09
for standard devices	
Low-action contacts	• KINAX 3W2 708-226D0
Snap-actiocontacts	• KINAX 3W2 708-226E0
Inductive contacts	

Fig. 3: Contact devices

1.2.3 Special functions



Fig. 4: Special functions

1.2.4 Assembly



Wall mounting



Pipe mounting



with panel mounting set

anel mounting set type 2 with front ring

Fig. 5: Assembly

The panel installation fittings can only be used in devices with a small measuring cell (\emptyset 75) and a display in the NG100 bayonet ring casing.



WARNING

Panel mounting set

Due to the heavy weight, the operator needs to install a support construction for installation of the front panel.

1.2.5 Equipment features (overview)

In the following, the equipment options of the DA01 are shown depending on the measuring cell used and the pressure stage.

NOTICE! Only single contacts, no changeover contacts possible.

Legend

- available
- □ on request

Small measuring cell Ø75

Measuring range	Measured value display Ø100	1	N Low-action contacts	3	1	 Snap-action contacts 	3	L Inductive contacts	Rotation angle transducer	Trailing needle	Marker needle	Remote seal	Pressure level
0 0.6 bar	•	•			•			•	•		•	•	
0 1 bar	•	•			•			•	•		٠	•	
0 1.6 bar	•	•			•			•	•		•	•	0
0 2.5 bar	•	•			•			•	•		•	•	N40
0 4.0 bar	•	•			•			٠	•		٠	•	50/P
0 6bar	•	•			•			•	•		•	•	N2(
0 10 bar	•	•			•			٠	•		٠	•	ц
0 16 bar	•	•			•			•	•		•	•	
0 25 bar	•	•			•			•	•		•	•	

Fig. 6: Small measuring cell Ø75 Measured value display Ø100

Measuring range	Measured value display Ø160	1	N Low-action contacts	3	1	 Snap-action contacts 	3	L Inductive contacts	Rotation angle transducer	Trailing needle	Marker needle	Remote seal	Pressure level
0 0.6 bar	•	•			•			•			•	•	
0 1 bar	•	•			•			•	•		٠	•	
0 1.6 bar	•	•			•			•	•		•	•	o
0 2.5 bar	•	•			•			•	•		•	•	N40
0 4.0 bar	•	•			•			•	٠		٠	•	50/P
0 6bar	•	•			•			•	•		•	•	N2ť
0 10 bar	•	•			•			•	•		٠	•	ш.
0 16 bar	•	•			•			•	•		•	•	
0 25 bar	•	•			•			•	•		•	•	

Fig. 7: Small measuring cell Ø75 Measured value display Ø160

Large measuring cell Ø130

Measuring range	Measured value display Ø100	1	N Low-action contacts	3	1	N Snap-action contacts	3	L Inductive contacts	2	Rotation angle transducer	Trailing needle	Marker needle	Remote seal	Pressure level
0 40 mbar	•											•		
0 60 mbar	•											•		
0 100 mbar	•											٠		250
0 160 mbar	•							•		•		•	•	Nd
0 250 mbar	•							٠		•		٠	•	
0 400 mbar	•							•		•		•	•	

Fig. 8: Large measuring cell Ø130 Measured value display Ø100

Measuring range	Measured value display Ø160	1	N Low-action contacts	3	1	N Snap-action contacts	3	L Inductive contacts	Rotation angle transducer	Trailing needle	Marker needle	Remote seal	Pressure level
0 40 mbar	•										•		
0 60 mbar	•										•		
0 100 mbar	•										•		250
0 160 mbar	•							•	•		٠	•	NA
0 250 mbar	•							•	•		٠	•	
0 400 mbar	•							•	•		•	•	

Fig. 9: Large measuring cell Ø130 Measured value display Ø160

1.3 Function diagram



Fig. 10: Function diagram

5

7

- 1 Motion train 3 Measuring shaft
- 2 4 Pressure transfer fluid
- Separating membrane 6
 - Connecting rod 8

Transfer lever

Pressure chamber

1.4 Design and mode of operation

Measuring diaphragm

The pressures in the pressure chambers that are to be compared are each exerted onto a measuring membrane that can be rigidly connected using a connection rod. To compensate the static pressure, the space between the separating and measuring membrane is filled with a pressure transfer fluid.

During pressure equalisation, the two measuring membranes are in an idle position. In case of pressure difference, the force acting on the membranes causes it to be moved towards the side of the lower pressure.

The connecting rod transfers the deflection of the measuring membranes onto the transfer lever mounted to the measuring shaft. Proportional to the current differential pressure, the measurement shaft makes a rotational movement that the indicator translates into a rotation angle between 0 and 270°.

In the case of one-sided pressure by the measuring system above and beyond the measuring range, the over-pressure guard will be activated which supports the overlosaded membrane.

2 Technical Data

2.1 Allgemeines

EXECUTION	Nominal pressure	Measuring cell	Application information
DA01 V	PN250	Ø75	Measuring ranges: 00.6 bar to 025 bar Remote seals: It is possible to attach remote seals for all measuring ranges. The re- mote seals need to be designed for the displacement volume, the length of the cable and the application temperature.
DA01 U	PN400	Ø75	Measuring ranges: 00.6 bar to 025 bar Remote seals: It is possible to attach remote seals for all measuring ranges. The re- mote seals need to be designed for the displacement volume, the length of the cable and the application temperature.
DA01 W	PN250	Ø130	Measuring ranges: 040 mbar to 0400 bar Limitations: Drag indicator measuring ranges ≥ 60 mbar Contacts / Transmitter measuring ranges ≥ 100 mbar Remote seals: It is possible to attach remote seals for measuring ranges ≥ 160 mbar. The remote seals need to be designed for the displacement volume, the length of the cable and the application temperature.

2.2 Input variables

Measuring variable

Differential pressure in gaseous and fluid aggressive media.

General

Rated pressure of the measuring system	Max. static operating pressure
Durability	One-sided over-pressure-proof up to the rated pressure of the measuring system resistance to under-pressure on the (+) and (-) side
Measurement accuracy	± 1.6 % of the measuring range (without contacts)
Temperature sensor	0.3 % / 10 °C
Zero-point adjustment	±25 % of the measuring range

Measuring ranges

Small measuring cell	Measuring range	Devi	Device model				
Ø75		V	U	W			
	0 … 0.6 bar	•	•				
	0 1 bar	•	•				
	0 … 1.6 bar	•	•				
	0 2.5bar	•	•				
	0 … 4.0 bar	•	•				
	0 … 6 bar	•	•				
	0 … 10 bar	•	•				
	0 … 16 bar	•	•				
	0 … 25 bar	•	•				
Large measuring cell	Measuring range	Devi	ce model				
Ø130		V	U	W			
	0 40 mbar			•			
	0 60 mbar			•			
	0 … 100 mbar			•			

0 ... 160 mbar

0 ... 250 mbar

0 ... 400 mbar

2.3 Operating conditions Permissible ambient temperature -20 ... +60 °C Admissible storage temperature -40 ... +80 °C Admissible media temperature < 85 °C Type of protection: IP 65 acc. to EN 60529

•

•

2.4 Construction design

Materials

	Measured value display	Material	Material no.							
			EU	AISI						
	Bayonet ring housing NG100, NG160	CrNi steel	1.4301	304						
	Process connection (all models)	CrNi steel	1.4404	316L						
	Intermediate plate	AIMgSiPb HARD-COAT®								
	Seals (O-rings)									
	Motion train	CrNi steel								
	Dial face and needle	Aluminium, painted	, printed							
	Inspection disk	Safety laminated gl	ass							
MB = Measurement	Materials (media-contacting)									
range	Design of the measuring system (R)	Material	Material	no.						
			EU	AISI						
	Pressure caps	CrNi steel	1.4404	316L						
	Separation membranes	CrNi steel	1.4571	361Ti						
	Design of the measuring system (G)	Material	Material	no.						
			EU	AISI						
	Pressure caps	CrNi steel	1.4404	316L						
	Separation membranes	Hastelloy® C276								
	Process connection	Material	Material no.							
			EU	AISI						
	Connecting piece and port	CrNi steel	1.4404	316L						

Assembly

Cutting ring screw connections

Wall mounting	Flanged assembly plate
Pipe mounting	Flanged assembly plate and attachment bracket
Panel mounting set type 1	Panel installation fittings for units with a small measuring cell (Ø75) and NG100 bayonet ring casing.
Panel mounting set type 2	Front ring and support construction

CrNi steel

1.4571

2.4.1 Additional Attachments

2.4.1.1 Contact elements

Limit signal transmitters (contacts) and capacitive rotation angle transducers with an output signal proportional to the angular position can be fitted into a housing augmented by a corresponding bayonet ring connector.

A certain minimum pressure level is required to operate this kind of contact element, which is why there is a lower limit for the mbar measuring ranges. This limit depends on the model type and is stated in the section ,General'.

CAUTION! By driving and switching the contacts, the measuring deviation increases to a total of $\pm 2.5\%$ of the measuring range.

For more information and the order key, please refer to the data sheet:

- for limit switch in data sheet KE
- for rotation angle converter in the data sheet KE09

2.4.1.2 Liquid filling

NOTICE! Only devices without contact element

Under difficult operating conditions such as vibrations, extreme pressure fluctuations or to prevent condensation in open-air installations, the housing can be filled with the following liquids:

- Glycerine
- · Silicon oil

2.4.1.3 Marker needle

A settable red marker can be attached to the scale to clearly show a certain pressure (limit value).

2.4.1.4 Trailing needle

The railing needle is 'dragged' with the measured value indicator. As there is no fixed connection between the two needles, one-off maximum values are stored. The trailing needle can be reset using an adjusting dial in the window. Trailing needles cannot be used in conjunction with contacts. A certain minimum pressure level is required to move the drag indicator, which is why there is a lower limit for the mbar measuring ranges. This limit depends on the model type and is stated in the section ,General'.

2.4.1.5 Shut-off fitting

3-spindle valve block PN 100, DN 5, can be directly flanged

- Type DZ3600SV2700
- Material 1.4571
- Functions: Shut-off, pressure compensation

2.4.2 Electrical connection

In the case of devices with additional electronic equipment, the connection is realised using a cable socket attached to the side and/or with a Han 7D connector on the power plant models. The pin assignment depends on the ordered mode and is stated in the data sheet KE or KE09.



Cable socket

Number of screw terminals	6 + 2PE
Rated current	See data sheet KE
Rated voltage	250 V
Cable diameter	up to 1.5 mm ² with wire protection
Cable screw connection	M20 x 1.5, terminal range 7 13 mm

HAN 7D

No. of crimp contacts	7 + PE
Rated current	See data sheet KE
Rated voltage	50 V
Cable diameter	1 mm ²
Cable screw connection	M20 x 1.5, terminal range 7 13 mm

2.4.3 Dimensional drawings

All dimensions in mm unless otherwise stated

Small measuring system (Ø75)





Flange based on DIN EN 61518



Wall mounting plate



Fig. 12: Dimensional drawing (Small measuring system Ø75)

2" pipe mounting



Fig. 13: Pipe mounting

Large measuring system (Ø130)





Flange based on DIN EN 61518



Wall mounting plate



d2

d1

Fig. 14: Dimensional drawing (Large measuring system Ø130)

Installation of front panel type 1

(only small measuring system Ø75 and NG100 display)



Fig. 15: Installation of front panel with panel fittings

Installation of front panel type 2



Examples:



Assembly on a mounting plate

Fig. 16: Installation of front panel with front ring



Mounting to a 2" pipe

Contact elements











Cutting ring connection G3/8 for 12 mm pipe



Fig. 17: Shutoff valve DZ3600SV2700

3

3 Order Codes



Device model:

[1]	Pressure level	Measuring cell
V	PN250	Ø75
U	PN400	Ø75
W	PN250	Ø130

Measuring range:

Small measuring system	[2.3]	Measuring range	De	evice mode	I
Ø75			V	U	W
	01	0 … 0.6 bar	•	•	
	02	0 1 bar	•	٠	
	03	0 1.6 bar	•	•	
	04	0 2.5bar	•	•	
	05	0 4.0 bar	•	•	
	06	0 6 bar	•	•	
	07	0 10 bar	•	•	
	08	0 16 bar	•	•	
	09	0 25 bar	•	•	
	99	Special measuring ranges	•	•	
Large measuring system	[2.3]	Measuring range	De	evice mode	I
Ø130			V	U	W
	57	- · · ·			•
	57	0 40 mbar			•
	57 58	0 40 mbar 0 60 mbar			•
	57 58 59	0 40 mbar 0 60 mbar 0 100 mbar			•
	57 58 59 60	0 40 mbar 0 60 mbar 0 100 mbar 0 160 mbar			•
	57 58 59 60 82	0 40 mbar 0 60 mbar 0 100 mbar 0 160 mbar 0 250 mbar			•
	57 58 59 60 82 83	0 40 mbar 0 60 mbar 0 100 mbar 0 160 mbar 0 250 mbar 0 400 mbar			•
	57 58 59 60 82 83 99	0 40 mbar 0 60 mbar 0 100 mbar 0 160 mbar 0 250 mbar 0 400 mbar Special measuring ranges			• • • • • • • •
	57 58 59 60 82 83 99 Design	 0 40 mbar 0 60 mbar 0 100 mbar 0 160 mbar 0 250 mbar 0 400 mbar Special measuring ranges of the measuring system: 			•

R	Pressure chamber CrNi steel 1.4404 (AISI 316L) Measuring membrane standard
G	Pressure chamber CrNi steel 1.4404 (AISI 316L)

Measuring membrane Hastelloy C276

Process connection:

[5.6]

- **03** Flange connection based on DIN EN 61518 with internal thread G¹/₂
- 04 Connecting piece G¹/₂ with inside thread 1/4 -18 NPT
- 05 Connecting piece G¹/₂ with inside thread 1/2 -14 NPT
- **13** Connection shanks $G^{1/2}$ with external thread $G^{1/2}$
- 14 Connecting port G¹/₂ with outer thread 1/4-18 NPT
 - 15 Connecting port G¹/₂ with outer thread 1/2-14 NPT
- 27 Cutting ring connection in brass for 12 mm pipe

Measured value display:

- L Bayonet ring housing NG100
- M Bayonet ring housing NG160

Assembly:

[8]	
W	Wall mounting
R	Pipe mounting
т	Panel installation fittings (only a small measuring system Ø75, NG100 measured value display without contact elements)
G	Front ring for panel mounting

Fluid filling:

[9]	Only devices without contact element	
0	Without fluid filling	
1	Glycerine	
4	Paraffin oil	
5	Silicon oil	
Special functions:		

[10]

- **0** Without special function
- 1 Adjustable marker needle
- 2 Resettable drag needle

Contacts/transmitters:

[11]

- **0** No contacts/transmitters
- 1 Built-in contacts as per data sheet KE
- 2 Installed capacitive rotation angle encoder in accordance with data sheet KE09
- 5 Built-in contacts with plug connector (power plant model)

Limitations

A minimum operating pressure, which not all measuring ranges achieve, is required to activate a contact element or a drag indicator. Please also note the information about the equipment features [> 5].

3.1 Accessories

Order no.	Planned measures	Material		
DZ3600SV2	700 Triple valve block DN5 PN420	1.4571		
	 Flange connection acc. to DIN EN 6² 	1518		
 Cutting ring screw connections 12 mm pipe 				
	 Including assembly set 			
•		_		
Order no.	Planned measures	Туре		
05003065	Isolating unit amplifier 1-channel 24 V DC	TS500Ex-ia-1R-5		
05003066	Isolating unit amplifier 2-channel 24 V DC	TS500Ex-ia-2R-5		
05003083	Isolating unit amplifier 1-channel 230 V AC	TS500Ex-ia-1R-0		
05003084	Isolating unit amplifier 2-channel 230 V AC	TS500Ex-ia-2R-0		
05003070	Universal supplier isolator	ST500Ex-10-5		
05003086	Universal supplier isolator	ST500Ex-10-0		

3.2 Information about the document

This document contains all technical data about the device. Great care was taken when compiling the texts and illustrations; Nevertheless, errors cannot be ruled out.

Subject to technical amendments.



FISCHER Mess- und Regeltechnik GmbH Bielefelder Str. 37a D-32107 Bad Salzuflen Tel. +49 5222-974-0 Fax. +49 5222-7170

web : <u>www.fischermesstechnik.de</u> eMail : <u>info@fischermesstechnik.de</u>