



TÜVRheinland®

DIN CERTCO

Genau. Richtig.

CERTIFICATE

Certificate holder

**FISCHER Mess- und Regeltechnik GmbH
Bielefelder Str. 37a
32107 Bad Salzuflen
GERMANY**

Product

Flow switches for heat transfer installations

Type, Model

NK10...

Testing basis

DIN 4754-3:2015-03
Zertifizierungsprogramm Strömungs- und Füllstandsicherungen DIN 4754-2, DIN 4754-3 (2016-01)

Mark of conformity



Registration No.

10F001

Valid until

2030-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2025-10-28

Dr. Ina Förster
Certification Body





ANNEX

Certificate

10F001 dated 2025-10-28

Technical Data

Measuring device: float system
Transfer of measured values: values: mechanically by float rod with bellow
Operating pressure: 6 bar, 10 bar and 16 bar (according to design)
Ambient temperature: -10 °C to +70 °C
Medium temperature: 350 °C and +400 °C (according to design)
Rated voltage: 250 V AC, 5 A and DC 30 V, 0,4 A
Installation position: horizontal

Testing laboratory/ Inspection body

TÜV Rheinland Industrie
Service GmbH
Am Grauen Stein
51105 Köln
GERMANY

Test report(s)

FBW 1810/15 dated 2015-10-07
968/FI 1018.00/18 dated 2018-09-24
968/FI 1018.01/19 dated 2019-09-27
968/FSP 2160.00/20 dated 2020-11-25
968/FSP 2160.01/25 dated 2025-06-25

