



TÜVRheinland®

DIN CERTCO

Genau. Richtig.

CERTIFICATE

Certificate holder

FISCHER Mess- und Regeltechnik GmbH
Bielefelder Str. 37a
32107 Bad Salzuflen
GERMANY

Product

Flow switches for heat transfer installations

Type, Model

DS21...

Testing basis

DIN 4754-2:2015-03
Zertifizierungsprogramm Strömungs- und Füllstandsicherungen DIN 4754-2, DIN 4754-3 (2016-01)

Mark of conformity



Registration No.

10S001

Valid until

2030-10-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2025-10-28

Dr. Ina Förster
Certification Body





ANNEX

Page 1 of 1

Certificate

10S001 dated 2025-10-28

Technical Data

Model: differential pressure gauge

Operating pressure: 6 bar, 10 bar and 16 bar (according to design)

Rated voltage: 250 V AC, 5 A or 30 V DC, 0,4 A

Switching hysteresis: 2,5 % accumulated value of measuring range

Testing laboratory/ Inspection body

TÜV Rheinland Industrie

Service GmbH

Am Grauen Stein

51105 Köln

GERMANY

Test report(s)

SSW 1710/15 dated 2015-10-07

968/FI 1018.00/18 dated 2018-09-24

968/FI 1018.01/19 dated 2019-09-27

968/FSP 2160.00/20 dated 2020-11-25

968/FSP 2160.01/25 dated 2025-06-25

