

UKCA Declaration of Conformity

For the product described as follows

Product designation **Differential Pressure Gauge**
(with transmitter for angular position KE0905#9)

Type designation **DA09 ... 20**

is hereby declared to comply with the essential requirements, specified in the following UK regulations:

Statutory regulation No.

2016 No. 1091

2022 No. 1647

2021 No. 422

Description

The Electromagnetic Compatibility Regulations 2016

The Hazardous Substances and Packaging (Legislative Functions and Amendment) (EU Exit) Regulations 2020

The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment (Amendment) Regulations 2021

The products have been tested according to the following standards.

Electromagnetic compatibility (EMC):

BS EN IEC 61000-6-2:2019-02-25

Electromagnetic compatibility (EMC). Generic standards. Immunity standard for industrial environments

BS EN IEC 61000-6-3:2021-03-30

Electromagnetic compatibility (EMC). Generic standards. Emission standard for equipment in residential environments

Restriction of Hazardous Substances (RoHS):

BS EN IEC 63000:2018-12-10

Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

The sole responsibility for drawing up this declaration of conformity in relation to the fulfilment of the essential requirements and the preparation of the technical documentation lies with the manufacturer.

Manufacturer

FISCHER Mess- und Regeltechnik GmbH

Bielefelder Str. 37a


32107 Bad Salzuflen, Germany

Tel. +49 (0)5222 974 0

The devices bear the following marking:

**UK
CA**

Bad Salzuflen
04 Okt 2021



G. Gödde
Managing director

